



City of Ashland Building Safety Division

51 Winburn Way • Ashland, OR 97520
 Phone (541) 488-5305 • Fax (541) 488-6066
 Email: Building@ashland.or.us

Wildfire Mitigation Plan Submittal Form

Instructions: Identify in each section how compliance with R327 Wildfire Hazard Mitigation requirements are achieved (Check and fill in information for all that applies).

Roofing (R327.3)

Note: There are additional requirements for preventing intrusion of embers and flames in open spaces between roofing and roof decking and additional flashing requirements

Material (Minimum Class B)	Manufacturer	Product Name	Fire-Resistance Rating Class A or B

Rain Gutters (R327.3.1)

Non-combustible rain gutter with non-combustible corrosion-resistant screening
--

Vents (Flame and Ember-Resistant): Eave, Soffit, Cornice, and Ceiling <12 feet above grade or surface below (R327.3.2.1)

Vented Roof (vents that are listed and tested by ASTM E2886, or Building Official approval)
Unvented Roof (see attachment, all conditions shall be met)

Location	Manufacturer	Product Name	Approval Listing #

All Other Vents (R327.3.2)

Material
Corrosion-resistant with maximum 1/8" non-combustible corrosion-resistant metal mesh

Exterior Wall Covering (R327.3.3)

Note: There are additional requirements for how wall coverings terminate. For combustible siding/wall covering, fill out the following table or explain how you will achieve requirements:

Location	Orientation	Material	Manufacturer	Product Name	Approval Listing #
One layer of minimum 5/8" exterior grade Type X behind covering or 1-hour fire-resistive assembly					



City of Ashland Building Safety Division

51 Winburn Way • Ashland, OR 97520
Phone (541) 488-5305 • Fax (541) 488-6066
Email: Building@ashland.or.us

Overhanging Projections, Roof Eaves, Soffits, Cornices, Patio/Porch Ceilings, or Underfloor Protection of Elevated Structures (R327.3.4.1)

Note: Gable end overhangs beyond an ext. wall other than at the lower end of rafter tails are exempt.

Location	Material	Manufacturer	Product Name	Approval Listing #
One layer of minimum 5/8" exterior grade Type X behind covering or 1-hour fire-resistive assembly				

Walking Surfaces (R327.3.5)

Note: Fill this in for any combustible surface decking material planned. If none, label N/A.

Material	Manufacturer	Product Name	Approval Listing #

Glazing in Windows, Doors, Skylights (R327.3.6)

Material
All, dual glazing, tempered glass, glass block, or a fire resistance rating of not less than 20 min.

Applicant Name _____

Applicant Signature _____

Date _____



City of Ashland Building Safety Division

51 Winburn Way • Ashland, OR 97520

Phone (541) 488-5305 • Fax (541) 488-6066

Email: Building@ashland.or.us

Attachment: Unvented Roofs

R806.5 Unvented attic and unvented enclosed rafter assemblies.

Unvented *attics* and unvented enclosed roof framing assemblies created by ceilings that are applied directly to the underside of the roof framing members and structural roof sheathing applied directly to the top of the roof framing members/rafters, shall be permitted where all the conditions are met:

1. The unvented *attic* space is completely within the *building thermal envelope*.
2. Interior Class I vapor retarders are not installed on the ceiling side (*attic* floor) of the unvented *attic* assembly or on the ceiling side of the unvented enclosed roof framing assembly.
3. A minimum insulation level of R-20 air-impermeable or rigid board insulation embedded into *air-permeable insulation* shall be installed above all recessed fixtures, such as recessed lights and exhaust fans.
4. Where wood shingles or shakes are used, a minimum ¼-inch (6.4mm) vented airspace separates the shingles or shakes and the roofing underlayment above the structural sheathing.
5. Any *air-impermeable insulation* shall be a Class II vapor retarder, or shall have a Class II vapor retarder coating or covering in direct contact with the underside of the insulation.
6. Insulation shall comply with Item 6.1, 6.2, or 6.3. Where preformed insulation board is used as the *air-impermeable insulation* layer as specified in the items below, it shall be sealed at the interior perimeter or each individual sheet to form a continuous layer.
 - 6.1 Where only *air-impermeable insulation* is provided, it shall be applied in direct contact with the underside of the structural roof sheathing.
 - 6.2 Where *air-permeable insulation* is installed directly below the structural sheathing, rigid board or sheet insulation shall be installed directly above the structural roof sheathing to an insulation level not less than R-20 for condensation control.
 - 6.3 Where both *air-impermeable* and *air-permeable insulation* are provided, the *air-impermeable insulation* shall be applied in direct contact with the underside of the structural roof sheathing to an insulation level not less than R-20 and shall be in accordance with the R-values in Table R806.5 for condensation control. The *air-permeable insulation* shall be installed directly under the *air-impermeable insulation*.